

**OFFICE OF THE EXECUTIVE ENGINEER
P.H. DIVISION, MUZAFFARPUR**

Letter No. :....2.6...../


Dated : 28/05/25/

REGARDING SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE

It is certified that an inspection team headed by **Sri Satya Prakash Azad, Chemist** from Public Health Division, Muzaffarpur (Name of Department/Office) inspected the **CAMBRIDGE PREP/PUBLIC SCHOOL, Gangapur, Panapur Haweli Kanti, Muzaffarpur, Bihar 843113** (Name of School) has safe drinking water facilities for the students and memories of staff of the institution and is maintaining the hygienic by the central/state/U.T. Govt.

The above is valid for a period of one year.


Chemist
R.W.T.L., Muzaffarpur
CHEMIST
R.W.T.L.; MUZAFFARPUR

To,
The Principal
Cambridge Prep.Public school,
Gangapur, Panapur Haweli Kanti,
Muzaffarpur, Bihar 843113

PUBLIC HEALTH ENGINEERING DEPARTMENT

Regional Water Testing Laboratory

District Name : Muzaffarpur

Month- MAY 2025

Sl. No.	Block	Panchayat	Village	Habitation/Ward	Location of Source	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alk	Fe	So ₄	Remarks
1	Kanti	Panapur Haveli	Gangapur	Gangapur	Cambridge Prep. Public School	7.02	1	376	144	110	25.2	10.6	15	80	0.21	25	
Acceptable Limit (IS 10500-2012)						6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75 mg/l	30 mg/l	250 mg/l	200 mg/l	1.0 mg/l	200 mg/l	
Permissible Limit in absence of alternate source (IS 10500-2012)						NR	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	NR	400 mg/l	


 CHEMIST
 R.W.T. MUZAFFARPUR